

1. Who is responsible for the supplying of the Power Service Panel PS1? DP&L or the contractor? **DP&L will provide power to pole on north side of Wagner Ave. (approx. Sta 59+38, 38.5' LT) Contractor is required to take it from the pole to the Power Service Panel.**
2. Can a cut sheet or drawing be issued as to what this panel is supposed to be? **ODOT SCD HL-40.20**
3. Is there a contact @ DP&L who can be reached to clarify this, as well as other misc questions such as fees that will need to be paid to DP&L for this work. **Bill Gourley – Direct: 937-331-4521, Cell: 937-608-2814**
4. Can a specific part or model number be provided, if necessary, for the in-line fuse holders required? No specific specification could be found. **Per ODOT 725.15 and SCD HL-60.12**